

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0065:105 Page 1 of 1

CATEGORY: Control Unit (High Rise)

LISTEE: Faraday Inc, 805 South Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Model 19000A Evac control panel is a modular control unit consists of model 19000A control unit (CSFM Listing No. 7165-0065:103) and audio voice/tone evacuation signals and an emergency telephone communication system. Local, auxiliary, remote station and proprietary receiving and protected premises service. Refer to listee's data sheet for additional detailed product description and operational considerations. The system consists of all components of Model 19000A (Refer to CSFM Listing No. 7165-0065:103) and the following:

401174/75/76	Tape Control Boards
401160/61	Speaker Control Module
401160/62	Relay Module
401150	Power Supply Module
401159	Timer
401677/77	Microphone Preamp Assembly
401163/64/66	Telephone Control Module
401152/53/54	Generator
401155	Supervisory Module
401158	Supervisory Board
401165	Telephone Extender
401170	Tape Player
401171	Power Distribution Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a high-rise fire alarm control unit for use with separately listed compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

Corrected 03-09-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager